

# Recall Information

## Edwards Signaling Heat Detector

Recall Date: June 17, 2020

Product Description	UPC	Model #	Internet #
Edwards Signaling Conventional Heat Detector, Fixed Temp	782640228555	283B-PL	204985099
Edwards Signaling Conventional Heat Detector, Rate-of-Rise and Fixed Temperature	782640228517	281B-PL	204985097



**Name of Product:** Edwards Signaling Conventional Heat Detector, Fixed Temp

**Hazard:** The recalled heat detectors can fail to activate in reaction to rising temperatures, posing a risk of failure to alert consumers to a fire.

**Remedy:** Free Replacement.

Consumers who use the product in life-safety applications permitted by code (for example, in elevator shafts, or in lieu of smoke detectors, manual pull stations, or sprinklers in particular settings), or in residential attics or residential garages, should immediately contact a fire or security alarm professional for free replacement and installation of the heat detector.

**Consumer Contact:** Edwards Fire Safety at 800-505-5088, or online at <https://edwardsfiresafety.com> and click on “Mechanical Heat Detector Information” for more information, or at <https://edwardsheatdetector.rsvpcomm.com>.

Post until October 18, 2020