

# Recall Information

## Triangle Tube Prestige Condensating Gas Boiler

Recall Date: July 28, 2020

Product Description	UPC	Model #	Internet #
Triangle Tube Prestige Solo 155 95% AFUE Condensating Gas Boiler with 120000-138000 BTU and 153000 Input Modulating	754094110823	PA155	302976020
Triangle Tube Prestige Solo 80 95% AFUE Condensating Gas Boiler with 63000-72000 BTU and 80000 Input Modulating	754094110809	PA80	302976017



**Name of Product:** Triangle Tube Prestige Condensating Gas Boiler

**Hazard:** Flue gas can escape from the gas boilers if the vent adapter is not securely reattached to the boiler after maintenance or repair, posing a carbon monoxide poisoning hazard to consumers.

**Remedy:** Repair.

Consumers with recalled boilers should immediately contact Triangle Tube to schedule a free repair. Consumers who continue using the boilers while awaiting repair should have working carbon monoxide alarms on each level of their homes and outside sleeping areas. Consumers who do not have a carbon monoxide alarm can contact Triangle Tube to have one shipped to them free of charge.

**Consumer Contact:** Triangle Tube toll-free at 877-574-5036 or online at [www.triangletube.com](http://www.triangletube.com) and click on "RECALL INFORMATION" for more information.

Post until November 28, 2020